

Manufacturer	Model	Rated Capacity (GPD)	Basis for Approval
Bio-Microbics, Inc.	RetroFast .25 <sup>1</sup>	250	ETV and Advisory Committee
	RetroFast .375 <sup>1</sup>	375	ETV and Advisory Committee
Bord na Mona	Puraflo	125 gallons per module	Experimental testing
Eco-Pure	<a href="#">Series 300</a>	600	Advisory Committee
E-Z Set Company	E-Z Treat System	600	Advisory Committee
Orenco	AX-20	600	Advisory Committee
Premier Tech	Ecoflo	600	Advisory Committee

All NSF International Standard 40 Class 1 aerobic treatment devices are authorized for use as a secondary treatment device pursuant to the requirements of the *Sewage Handling and Disposal Regulations*. A list of the devices may be found on the NSF International website:

<http://www.nsf.org/certified/wastewater/Listings.asp?TradeName=&Standard=>

<sup>1</sup> **Note:** The RetroFast .25 and the RetroFast .375 units are approved for use only with 1 and 2 bedroom homes respectively. No flow reduction is allowed for water saving fixtures when either of these systems are used